

**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	220000442
<b>Drinking-Water System Name:</b>	Sturgeon Falls Water Treatment Plant
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of West Nipissing
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2020 to December 31, 2020

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;">                 Sturgeon Falls Water Treatment Plant                  11 Nipissing Street, Sturgeon Falls, ON             </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve?                  Yes [ ] No [ ] Not Applicable [x]</p> <p>Number of Interested Authorities you report to: <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?                  Yes [ ] No [ ] Not Applicable [x]</p>
--	--

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [ ] No [ ] Not Applicable [x]

**Indicate how you notified system users that your annual report is available, and is free of charge.**

**[x] Public access/notice via the web**

**Describe your Drinking-Water System**

The Sturgeon Falls WTP commissioned in 1991, consists of a full surface water treatment facility, with a design capacity of 14 200 m<sup>3</sup>/day, drawing water from the Sturgeon River.

The process consists of:

- Intake from the Sturgeon River, equipped with manually removable screens
- Four vertical turbine raw water pumps
- Two up-flow pre-treatment tanks for flash mixing for chemical assisted flocculation and sedimentation
- Four sets of three-cells-in-series flocculation tanks
- Two rectangular settling tanks, each with an inclined plate settling system
- Three anthracite/sand gravity filters, each with continuous turbidity monitoring
- Chlorine gas for primary disinfection
- One chlorine contact tank equipped with baffle walls, and discharge line to the underground reservoir
- Continuous Giardia log removal calculations to monitor adequacy of disinfection
- Hydrated lime (calcium hydroxide) addition for pH and alkalinity control
- Two cell in-ground storage reservoir
- A two-chamber clear well
- Five vertical turbine type high lift pumps to Distribution
- Post-chlorine gas addition to Distribution with continuous monitoring
- Hydrofluosilicic acid (fluoride) addition to Distribution with continuous monitoring
- Filter backwash system consisting of two filter backwash pumps, serving all filters
- Backwash wastewater discharge to the backwash settling tanks
- Three backwash settling tanks; supernatant return to Sturgeon River; settled sludge to sludge thickening tanks
- Two square sludge thickening tanks; sludge discharge to municipal sewage collection system; supernatant return to the Sturgeon River
- Back-up diesel powered generator capable of servicing essential plant operations

**List all water treatment chemicals used over this reporting period**

- Polyaluminum chloride – for coagulation
- Specialty polymer – a coagulant aid
- Limestone – for raw water alkalinity adjustments to improve coagulation
- Chlorine (gas) – for primary and secondary disinfection
- Hydrated lime (calcium hydroxide) – for finished water pH adjustment
- Hydrofluosilicic acid – fluoridation
- Corrosion control and manganese sequesterant

### Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment
- Not Applicable

### Please provide a brief description and a breakdown of monetary expenses incurred

Water Plant Material/Supplies/Rentals/Maintenance	\$151,186
Water Plant Process Chemicals	\$138,753
Water Quality Lab Testing	\$283,598
Consulting/Operator Training	\$179,794
Water Plant Utilities	\$20,693
Insurance	\$17,548
Labour	\$40,265
Electrical/Instrumentation	\$19,578

### Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Units	Corrective Action	Corrective Action Date
	Nil				

### Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Results CFU/100mL (min #)-(max #)	Range of Total Coliform Results CFU/100mL (min #)-(max #)
<b>Raw</b>	52	0 – 80*	70 – 1770*
<b>Treated</b>	52	0 – 0	0 – 0
<b>Distribution</b>	260	0 – 0	0 – 0

\* NDOGT (No Data Overgrown with Target) for July 20 and 27, and August 10, 17 and 31 samples.

### Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
<b>Turbidity</b>	8760	Daily Peak: 0.055 - 0.113 NTU
<b>Chlorine</b>	8760	Daily Average: 0.93 - 1.89 mg/L
<b>Fluoride</b>	8760	Daily Average: 0.00 - 0.88 mg/L

**NOTE:** For continuous monitors use 8760 as the number of samples.

## Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Sampled	Result	Unit of Measure
March 31, 2016 – MDWL 202-102	Backwash SS	38 samples	3.1	mg/L (annual average)

## Summary of Inorganic and Organic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Fluoride	2020-07-28	< 0.1	mg/L	No
Nitrite (N)	2019-03-18	< 0.1	mg/L	No
	2020-05-21	< 0.1		No
	2020-07-28	< 0.1		No
	2020-10-28	< 0.1		No
Nitrate (N)	2019-03-18	< 0.1	mg/L	No
	2020-05-21	< 0.1		No
	2020-07-28	< 0.1		No
	2020-10-28	< 0.1		No
Haloacetic Acids (Running Annual Averages)	2019-03-18	27.3 (35.8)	µg/L	No
	2020-07-28	39.2 (36.5)		No
	2020-07-28	87.7 (49.4)		No
	2020-10-28	78.1 (58.1)		No
Antimony	2020-07-28	< 0.0001	mg/L	No
Arsenic	2020-07-28	0.0003	mg/L	No
Barium	2020-07-28	0.014	mg/L	No
Boron	2020-07-28	< 0.005	mg/L	No
Cadmium	2020-07-28	< 0.000015	mg/L	No
Chromium	2020-07-28	< 0.002	mg/L	No
Lead	2020-07-28	0.00008	mg/L	No
Mercury	2020-07-28	< 0.00002	mg/L	No
Selenium	2020-07-28	< 0.001	mg/L	No
Sodium	2020-07-28	1.2	mg/L	No
Uranium	2020-07-28	< 0.00005	mg/L	No
Benzene	2020-07-28	< 0.5	µg/L	No
Carbon Tetrachloride	2020-07-28	< 0.2	µg/L	No
Dichlorobenzene, 1,2-	2020-07-28	< 0.5	µg/L	No
Dichlorobenzene, 1,4-	2020-07-28	< 0.5	µg/L	No
Dichloroethane, 1,2-	2020-07-28	< 0.5	µg/L	No
Dichloroethene, 1,1-	2020-07-28	< 0.5	µg/L	No
Dichloromethane (Methylene Chloride)	2020-07-28	< 5	µg/L	No
Monochlorobenzene (Chlorobenzene)	2020-07-28	< 0.5	µg/L	No
Tetrachloroethylene	2020-07-28	< 0.5	µg/L	No
Trichloroethylene	2020-07-28	< 0.5	µg/L	No
Vinyl Chloride	2020-07-28	< 0.2	µg/L	No
Total Trihalomethanes (Running Annual Averages)	2019-03-18	36 (43.5)	µg/L	No
	2020-05-21	66 (48.0)		No
	2020-07-28	58 (50.3)		No
	2020-10-28	63 (55.8)		No
Alachlor	2020-07-28	< 0.3	µg/L	No

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Atrazine + Metabolites	2020-07-28	< 0.5	µg/L	No
Azinphos-methyl	2020-07-28	< 1	µg/L	No
Benzo(a)pyrene	2020-07-28	< 0.005	µg/L	No
Bromoxynil	2020-07-28	< 0.5	µg/L	No
Carbaryl	2020-07-28	< 3	µg/L	No
Carbofuran	2020-07-28	< 1	µg/L	No
Chlorpyrifos	2020-07-28	< 0.5	µg/L	No
Diazinon	2020-07-28	< 1	µg/L	No
Dicamba	2020-07-28	< 10	µg/L	No
Dichlorophenol, 2,4-	2020-07-28	< 0.1	µg/L	No
Dichlorophenoxy acetic acid, 2,4- (2,4-D)	2020-07-28	< 10	µg/L	No
Diclofop-methyl	2020-07-28	< 0.9	µg/L	No
Dimethoate	2020-07-28	< 1	µg/L	No
Diquat	2020-07-28	< 5	µg/L	No
Diuron	2020-07-28	< 5	µg/L	No
Glyphosate	2020-07-28	< 25	µg/L	No
Malathion	2020-07-28	< 5	µg/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA)	2020-07-28	< 10	mg/L	No
Metolachlor	2020-07-28	< 3	µg/L	No
Metribuzin	2020-07-28	< 3	µg/L	No
Paraquat	2020-07-28	< 1	µg/L	No
Pentachlorophenol	2020-07-28	< 0.1	µg/L	No
Phorate	2020-07-28	< 0.3	µg/L	No
Picloram	2020-07-28	< 20	µg/L	No
Poly-Chlorinated Biphenyls (PCB's)	2020-07-28	< 0.05	µg/L	No
Prometryne	2020-07-28	< 0.1	µg/L	No
Simazine	2020-07-28	< 0.5	µg/L	No
Terbufos	2020-07-28	< 0.3	µg/L	No
Tetrachlorophenol, 2,3,4,6-	2020-07-28	< 0.1	µg/L	No
Triallate	2020-07-28	< 10	µg/L	No
Trichlorophenol 2,4,6-	2020-07-28	< 0.1	µg/L	No
Trifluralin	2020-07-28	< 0.5	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nil			

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)