

**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	220000442
<b>Drinking-Water System Name:</b>	Sturgeon Falls Water Treatment Plant
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of West Nipissing
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2023 to December 31, 2023

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;">                 Sturgeon Falls Water Treatment Plant                  11 Nipissing Street, Sturgeon Falls, ON             </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve?                  Yes [ ] No [ ] Not Applicable [x]</p> <p>Number of Interested Authorities you report to: <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?                  Yes [ ] No [ ] Not Applicable [x]</p>
--	--

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [ ] No [ ] Not Applicable [x]

**Indicate how you notified system users that your annual report is available, and is free of charge.**

**Public access/notice via the web**

**Describe your Drinking-Water System**

The Sturgeon Falls WTP commissioned in 1991, consists of a full surface water treatment facility, with a design capacity of 14 200 m<sup>3</sup>/day, drawing water from the Sturgeon River.

The process consists of:

- Intake from the Sturgeon River, equipped with manually removable screens
- Four vertical turbine raw water pumps
- Two up-flow pre-treatment tanks for flash mixing for chemical assisted flocculation and sedimentation
- Four sets of three-cells-in-series flocculation tanks
- Two rectangular settling tanks, each with an inclined plate settling system
- Three anthracite/sand gravity filters, each with continuous turbidity monitoring
- Chlorine gas for primary disinfection
- One chlorine contact tank equipped with baffle walls, and discharge line to the underground reservoir
- Continuous Giardia log removal calculations to monitor adequacy of disinfection
- Hydrated lime (calcium hydroxide) addition for pH and alkalinity control
- Two cell in-ground storage reservoir
- A two-chamber clear well
- Five vertical high lift turbine pumps to Distribution
- Post-chlorine gas addition to Distribution with continuous monitoring
- Hydrofluosilicic acid (fluoride) addition to Distribution with continuous monitoring
- Filter backwash system consisting of two filter backwash pumps, serving all filters
- Backwash wastewater discharge to the backwash settling tanks
- Three backwash settling tanks; supernatant return to Sturgeon River; settled sludge to sludge thickening tanks
- Two square sludge thickening tanks; sludge discharge to municipal sewage collection system; supernatant return to the Sturgeon River
- Back-up diesel powered generator capable of servicing essential plant operations

**List all water treatment chemicals used over this reporting period**

- Polyaluminum chloride – for coagulation
- Specialty polymer – a coagulant aid
- Limestone – for raw water alkalinity adjustments to improve coagulation
- Chlorine (gas) – for primary and secondary disinfection
- Hydrated lime (calcium hydroxide) – for finished water pH adjustment
- Hydrofluosilicic acid – fluoridation
- Corrosion control and manganese sequesterant

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment
- Not Applicable

**Please provide a brief description and a breakdown of monetary expenses incurred**

Item	Water Plant	Distribution
Material/Supplies/Rentals/Maintenance	\$129,485	\$131,490
Process Chemicals	\$204,460	
Water Quality Lab Testing	\$16,238	
Consulting/Operator Training	\$11,828	\$4,250
Utilities	\$177,462	\$1,151
Insurance	\$64,771	\$30,333
Labour	\$292,374	\$431,660
Electrical/Instrumentation	\$23,315	
<b>Total</b>	<b>\$919,933</b>	<b>\$598,885</b>

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Units	Corrective Action	Corrective Action Date
	Nil				

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Results CFU/100mL (min #)-(max #)	Range of Total Coliform Results CFU/100mL (min #)-(max #)
Raw	52	1 – 110*	26 – 730*
Treated	52	0 – 0	0 – 0
Distribution	260	0 – 0	0 – 0

\* NDOGT (No Data Overgrown with Target) for January 16, July 4, July 10, July 17, July 31, and August 21 samples.

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	Daily Peak: 0.016 – 0.315 NTU
Chlorine	8760	Daily Average: 0.88 – 1.83 mg/L
Fluoride	359	Daily Average: 0.12 – 1.09 mg/L

**NOTE:** For continuous monitors use 8760 as the number of samples.

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Sampled	Result	Unit of Measure
Feb. 18, 2021 – MDWL 202-102	Waste Residue Total Suspended Solids	46 samples	23.3	mg/L (annual average)

**Summary of Inorganic and Organic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Fluoride	2023-07-17	0.6	mg/L	No
Nitrite (N)	2023-01-11	< 0.1	mg/L	No
	2023-04-19	< 0.05		No
	2023-07-17	< 0.05		No
	2023-10-21	< 0.05		No
Nitrate (N)	2023-01-11	0.1	mg/L	No
	2023-04-19	0.08		No
	2023-07-17	< 0.05		No
	2023-10-21	< 0.05		No
Haloacetic Acids (Running Annual Averages)	2023-01-11	37.6 (38.6)	µg/L	No
	2023-04-19	40.7 (43.2)		No
	2023-07-17	66.1 (49.8)		No
	2023-10-21	52.3 (49.2)		No
Antimony	2023-11-09	< 0.0001	mg/L	No
Arsenic	2023-11-09	0.0002	mg/L	No
Barium	2023-07-17	0.010	mg/L	No
	2023-11-09	0.011		
Boron	2023-07-17	< 0.005	mg/L	No
	2023-11-09	< 0.005		
Cadmium	2023-11-09	< 0.000015	mg/L	No
Chromium	2023-11-09	< 0.0010	mg/L	No
Lead	2023-07-17	0.00015	mg/L	No
Mercury	2023-07-17	0.00003	mg/L	No
	2023-11-09	<0.00002		
Selenium	2023-11-09	<0.001	mg/L	No
	2023-11-09	<0.001		
Sodium	2023-07-17	1.2	mg/L	No
Uranium	2023-11-09	<0.00005	mg/L	No
Benzene	2023-07-17	< 0.5	µg/L	No
Carbon Tetrachloride	2023-07-17	< 0.2	µg/L	No
Dichlorobenzene,1,2-	2023-07-17	< 0.5	µg/L	No
Dichlorobenzene,1,4-	2023-07-17	< 0.5	µg/L	No
Dichloroethane,1,2-	2023-07-17	< 0.5	µg/L	No
Dichloroethene, 1,1-	2023-07-17	< 0.5	µg/L	No
Dichloromethane (Methylene Chloride)	2023-07-17	< 5	µg/L	No
Monochlorobenzene (Chlorobenzene)	2023-07-17	< 0.5	µg/L	No
Tetrachloroethylene	2023-07-17	< 0.5	µg/L	No
Trichloroethylene	2023-07-17	< 0.5	µg/L	No
Vinyl Chloride	2023-07-17	< 0.2	µg/L	No

Total Trihalomethanes (Running Annual Averages)	2023-01-11 2023-04-19 2023-07-17 2023-10-21	57.0 (49.8) 33.0 (48.0) 63.0 (50.5) 69.0 (55.5)	µg/L	No No No No
Alachlor	2023-07-17	< 0.3	µg/L	No
Atrazine + Metabolites	2023-07-17	< 0.5	µg/L	No
Azinphos-methyl	2023-07-17	< 1	µg/L	No
Benzo(a)pyrene	2023-07-17	< 0.006	µg/L	No
Bromoxynil	2023-07-17	< 0.5	µg/L	No
Carbaryl	2023-07-17	< 3	µg/L	No
Carbofuran	2023-07-17	< 1	µg/L	No
Chlorpyrifos	2023-07-17	< 0.5	µg/L	No
Diazinon	2023-07-17	< 1	µg/L	No
Dicamba	2023-07-17	< 1.0	µg/L	No
Dichlorophenol, 2,4-	2023-07-17	< 0.2	µg/L	No
Dichlorophenoxy acetic acid, 2,4- (2,4-D)	2023-07-17	< 1.0	µg/L	No
Diclofop-methyl	2023-07-17	< 0.9	µg/L	No
Dimethoate	2023-07-17	< 1	µg/L	No
Diquat	2023-07-17	< 5	µg/L	No
Diuron	2023-07-17	< 5	µg/L	No
Glyphosate	2023-07-17	< 25	µg/L	No
Malathion	2023-07-17	< 5	µg/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA)	2023-07-17	< 10	mg/L	No
Metolachlor	2023-07-17	< 3	µg/L	No
Metribuzin	2023-07-17	< 3	µg/L	No
Paraquat	2023-07-17	< 1	µg/L	No
Pentachlorophenol	2023-07-17	< 0.2	µg/L	No
Phorate	2023-07-17	< 0.3	µg/L	No
Picloram	2023-07-17	< 5.0	µg/L	No
Poly-Chlorinated Biphenyls (PCB's)	2023-07-17	< 0.05	µg/L	No
Prometryne	2023-07-17	< 0.1	µg/L	No
Simazine	2023-07-17	< 0.5	µg/L	No
Terbufos	2023-07-17	< 0.5	µg/L	No
Tetrachlorophenol, 2,3,4,6-	2023-07-17	< 0.2	µg/L	No
Triallate	2023-07-17	< 10	µg/L	No
Trichlorophenol 2,4,6-	2023-07-17	< 0.2	µg/L	No
Trifluralin	2023-07-17	< 0.5	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nil			

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non-municipal year-round residential, large non-municipal non-residential)