



Date: March 22, 2024

Contract Number: 2024-15

**West Nipissing Sewer and Watermain Upgrades
King and Ethel Street**

Addendum #1

1. General:

- .1 The Tender Document is amended as set forth in this Addendum. The original documents remain in full force and effect, except as amended by this Addendum, which is hereby made part of the Contract Documents.
- .2 Proponents/bidders are advised that the Owner does not, in any way, shape or form warrant the accuracy of the information relating to existing conditions, including but not limited to existing layout, subsurface condition, and utility information, that are stated or implied in these documents.
- .3 Please note it is the sole responsibility of the proponent/bidder to confirm receipt of ALL Addenda by including a signed and sealed version of each with their proposal. Failure to do so may result in the proposal being considered informal.

2. Scope:

- .1 The purpose of this addendum is to clarify questions received.
- .2 The **Tender** submittal deadline **has not changed** as a result of this Addendum.

3. Clarification to Questions:

- .1 The following hydrant models shall be used:
 - a. Mueller Century
 - b. Clow M67 Brigadier McAvity

Hydrants shall have 2 ½ " threaded sewer nozzles and 100mm STORZ pumper port.

4. Confirmation:

- .1 The proponent/bidder shall sign this Addendum in the space provided below, shall affix his seal hereto and shall include this Addendum to the Owner in the same envelope as their submission.
- .2 All terms and conditions of the original documents remain in full force and effect, and time shall be of the essence.



.3 The proponent/bidder shall enter this Addendum number in the provided Submission Form.

Signature

Affix Corporate Seal Above

End of Addendum #1.