



ADDENDUM NO.1

September 22nd -2025

Re: 2025-028 Lavigne Fire Department Shingles Replacement

The following Addendum shall be part of the Bid Document and shall supersede the bid specification sheets in Bid package.

INDICATE RECEIPT OF THIS ADDENDUM ON THE BID FORM.

This Addendum consists of 1 page.

Section 4 SPECIAL PROVISION

SCOPE OF WORK

Delete

2.10) Supply and install new overhead door frame and caulking.

UNDERLAYMENT

6.2) Installation

Delete

iii) Eave protection; Install ice and water shield at mansard roof minimum 900mm up the roof slope to a line not less than 300mm inside the inner face of the exterior wall.

And replace it with:

iii) Eave protection; Install ice and water shield at mansard roof and 6 feet up the roof slope.

SHINGLES

11.0) Materials

ADD

i) Approved materials; IKO Dynasty